

Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

### MILL TEST CERTIFICATE

**Customer:** PRODALAM S.A.  
**Commodity:** PRESTRESSED CONCRETE STRAND  
**Nominal Diameter:** 15.24 MM  
**Standard:** ASTM A416/A416M-18  
**Production Licence No:** XK 05-003-00098  
**Page No:** 1/4  
**Inspection Date:** NOV. 30TH, 2024  
**Invoice No:** PCLPY2404C  
**Container No:** BMOU2019033

Mark on Coil	Coil No.	Dia MM	Section Area (mm <sup>2</sup> )	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
14	2411103-5	15.22	140.13	272.1	1944	247.0	1764	5.0	191.8	2822	3146
14	2411103-6	15.24	140.13	273.7	1955	258.6	1847	4.9	196.7	2930	3266
14	2411104-6	15.26	140.64	272.3	1945	252.9	1806	5.1	195.8	2941	3278
14	2411105-5	15.27	141.27	272.9	1949	253.6	1811	5.1	198.7	2856	3184
14	2411106-2	15.24	140.13	272.4	1946	250.1	1786	5.2	195.5	2632	2936
14	2411106-3	15.24	140.13	272.2	1944	254.8	1820	5.0	196.0	2632	2936
14	2411106-4	15.24	140.13	271.5	1939	252.5	1804	5.3	192.3	2631	2934
14	2411106-5	15.24	140.13	271.6	1940	251.9	1799	5.4	197.8	2618	2920
14	2411106-6	15.24	140.13	271.3	1938	251.4	1796	5.3	193.4	2829	3154

Quality objection: The buyer shall notify the seller in writing by email of any non-conformity of the quantity or quality of the subject matter within three months after arrival at the port. Where the buyer delays in giving notice beyond the prescribed time limit, the quantity or quality of the subject matter is deemed to be in conformity with the contract.

Filed by :Zhangchunting

Approved by : Shenyingsiang