



**MILL TEST CERTIFICATE**

**Customer:** PRODALAM S.A.  
**Commodity:** PRESTRESSED CONCRETE STRAND  
**Nominal Diameter:** 15.24MM  
**Standard:** ASTM A416/A416M-15  
**Production Licence No:** XK 05-003-00098  
**Page No:** 14/14  
**Inspection Date:** FEB.5th,2022  
**Invoice No:** PCLPY2301C  
**Container No.** MEDU1486630



Mark on Coil	Coil No.	Dia MM	Section Area (mm <sup>2</sup> )	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
B16	2302307-3	15.27	140.89	272.0	1943	250.8	1791	5.5	198.3	2646	2946
B16	2302307-4	15.27	140.89	271.2	1937	249.0	1779	5.3	192.8	2449	2728
B16	2302307-5	15.27	140.89	272.0	1943	251.0	1793	5.0	197.3	2648	2948
B16	2302308-2	15.28	141.02	270.9	1935	251.2	1794	5.2	191.6	2854	3176
B16	2302308-3	15.28	141.02	270.4	1931	250.4	1789	5.3	192.7	2852	3174
B16	2302308-4	15.28	141.02	270.2	1930	249.5	1782	5.5	198.4	2854	3176
B16	2302308-5	15.28	141.02	271.4	1939	250.6	1790	5.4	191.6	2861	3184
B16	2302308-6	15.28	141.02	270.9	1935	251.2	1794	5.3	192.5	2832	3152
B16	2302516-6	15.28	140.89	274.0	1957	254.0	1814	5.0	190.6	2926	3256

**Filled by :Zhangchunting**

**Approved by : Shenyingsiang**