



QINGDAO GLOBAL OVERSEAS IMP&EXP CO., LTD

Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24 MM
Standard: ASTM A416/A416M-18
Production Liscence No: XK 05-003-00098
Page No: 1/8
Inspection Date: Aug.21th,2023
Invoice No: PCLPID2307C
Container No. APZU3879280



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
A11	2308369-2	15.28	141.27	270.8	1934	248.1	1772	5.1	194.3	2843	3170
A11	2308369-3	15.28	141.27	270.6	1933	247.9	1771	5.0	195.7	2847	3174
A11	2308369-4	15.28	141.27	270.2	1930	245.6	1754	4.8	196.4	2847	3174
A11	2308369-5	15.28	141.27	270.0	1929	245.8	1756	4.9	194.8	2843	3170
A11	2308369-6	15.28	141.27	269.7	1926	245.9	1756	4.7	191.7	2928	3264
A11	2308370-1	15.28	141.27	273.6	1954	250.4	1789	5.2	198.5	2459	2744
A11	2308370-2	15.28	141.27	273.4	1953	250.0	1786	5.1	197.3	2458	2742
A11	2308370-7	15.28	141.27	273.7	1955	249.9	1785	4.8	198.2	2706	3018
A11	2308146-2	15.30	141.66	271.6	1940	253.7	1812	4.8	198.3	2870	3200

Quality objection: The buyer shall notify the seller in writing by email of any non-conformity of the quantity or quality of the subject matter within three months after arrival at the port. Where the buyer delays in giving notice beyond the prescribed time limit, the quantity or quality of the subject matter is deemed to be in conformity with the contract.

Filled by :Zhangchunting

Approved by : Shenyangxiang