



MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Licence No: XK 05-003-00098
Page No: 9/14
Inspection Date: FEB.5th,2022
Invoice No: PCLPY2301C
Container No. TRHU2280656



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
B11	2302503-3	15.25	140.64	272.7	1948	254.7	1819	4.8	197.9	3032	3374
B11	2302504-6	15.24	140.51	269.8	1927	251.0	1793	5.0	198.3	2854	3176
B11	2301342-6	15.30	141.15	271.0	1936	251.0	1793	5.0	198.1	2989	3326
B11	2302510-3	15.27	140.89	271.7	1941	252.2	1801	4.9	195.2	2838	3158
B11	2302510-4	15.27	140.89	271.2	1937	253.8	1813	4.9	195.4	2839	3160
B11	2302510-5	15.27	140.89	271.5	1939	252.6	1804	5.0	196.4	2839	3160
B11	2302511-1	15.26	140.76	271.2	1937	254.7	1819	4.7	193.7	2439	2716
B11	2302511-2	15.26	140.76	271.4	1939	254.0	1814	4.8	194.5	2440	2718
B11	2302511-7	15.26	140.76	271.6	1940	248.7	1776	5.0	196.6	2688	2992

Filed by :Zhangchunting

Approved by : Shenyingsiang