



QINGDAO GLOBAL OVERSEAS IMP&EXP CO., LTD

Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 9.53MM
Standard: ASTM A416/A416M-15
Production Licence No: XK 05-003-00098
Page No: 2/2
Inspection Date: SEP.23, 2022
Invoice No: PCLPY2201C
Container No. ECMU1739271



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
C2	2209125-4	9.48	54.27	105.4	1916	94.2	1713	5.7	193.9	6870	2968
C2	2209126-4	9.52	54.78	107.0	1945	97.6	1775	5.0	196.0	8023	3464
C2	2209126-5	9.52	54.78	106.4	1935	98.1	1784	5.1	198.3	6893	2978
C2	2209126-6	9.52	54.78	106.6	1938	96.8	1760	5.0	191.3	6702	2896
C2	2209127-1	9.49	54.52	105.9	1925	98.5	1791	5.2	198.9	7205	3112
C2	2209127-2	9.49	54.52	105.7	1922	98.3	1787	5.1	198.7	7205	3112
C2	2209127-3	9.49	54.52	105.5	1918	98.1	1784	5.0	198.5	6888	2976
C2	2209127-5	9.49	54.52	105.3	1915	96.3	1751	5.1	199.1	7223	3120
C2	2209127-6	9.49	54.52	105.7	1922	95.5	1736	5.2	198.5	6860	2964

Filled by: Zhangchunting

Approved by: Shenyangxiang