



QINGDAO GLOBAL OVERSEAS IMP&EXP CO., LTD

Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

MILL TEST CERTIFICATE

Customer:

PRODALAM S.A.

Commodity:

PRESTRESSED CONCRETE STRAND

Nominal Diameter:

15.24MM

Standard:

ASTM A416/A416M-15

Production Liscence No:

XK 05-003-00098

Page No:

1/4

Inspection Date:

MAR.28TH,2023

Invoice No:

PCLPID2304C-1

Container No.

MEDU1481963



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
B2	2303397-5	15.27	141.40	271.0	1936	247.6	1769	6.0	195.1	2566	2862
B2	2303398-1	15.28	141.40	276.2	1973	258.6	1847	5.3	198.5	2456	2740
B2	2303398-2	15.28	141.40	272.8	1949	251.6	1797	5.5	191.3	2454	2738
B2	2303400-6	15.27	141.15	274.6	1961	251.6	1797	5.0	196.9	2492	2780
B2	2303401-2	15.27	141.91	276.1	1972	254.6	1819	5.1	194.1	3059	3410
B2	2303401-5	15.27	141.91	275.9	1971	252.1	1801	5.3	198.1	2861	3190
B2	2303401-6	15.27	141.91	275.6	1969	251.4	1796	5.3	194.6	2809	3132
B2	2303402-4	15.23	140.76	270.6	1933	245.1	1751	5.2	196.8	3038	3386
B2	2303402-5	15.23	140.76	270.8	1934	247.9	1771	5.1	191.8	3038	3386

Filled by :Zhangchunting

Approved by : Shenyingsiang