



QINGDAO GLOBAL OVERSEAS IMP&EXP CO., LTD

Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Liscence No: XK 05-003-00098
Page No: 2/4
Inspection Date: MAR.28TH,2023
Invoice No: PCLPID2304C-2
Container No. FCIU3470158



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
B1	2303394-3	15.23	140.51	271.4	1939	250.4	1789	4.9	191.1	3031	3378
B1	2303394-6	15.23	140.51	271.7	1941	244.8	1749	5.4	191.0	2514	2804
B1	2303395-6	15.32	141.27	271.5	1939	245.6	1754	5.1	192.9	2450	2734
B1	2303397-1	15.27	141.40	269.7	1926	250.6	1790	5.1	190.8	2847	3174
B1	2303397-2	15.27	141.40	269.9	1928	250.4	1789	5.0	190.6	2852	3180
B1	2303397-3	15.27	141.40	269.0	1921	250.0	1786	4.8	190.4	3013	3358
B1	2303397-4	15.27	141.40	272.5	1946	245.9	1756	5.4	193.4	2856	3184
B1	2303398-7	15.28	141.40	272.8	1949	254.0	1814	5.2	195.3	2371	2646
B1	2303399-2	15.33	141.91	271.0	1936	251.4	1796	5.0	193.6	2868	3198

Filled by :Zhangchunting

Approved by : Shenyangxiang