



MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Lisence No: XK 05-003-00098
Page No: 12/12
Inspection Date: Jan.4th,2022
Invoice No: PCLPY2205C
Container No. CMAU1767877



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
C12	2301311-6	15.30	141.53	275.9	1971	250.4	1789	4.9	196.2	2697	3002
C12	2301312-1	15.25	140.64	277.3	1981	255.9	1828	5.0	198.7	2646	2946
C12	2301312-2	15.25	140.64	276.6	1976	254.6	1819	5.1	194.1	2646	2946
C12	2301312-3	15.25	140.64	276.2	1973	252.9	1806	4.9	192.6	2648	2948
C12	2301312-4	15.25	140.64	275.1	1965	253.1	1808	5.0	190.2	2760	3072
C12	2301312-5	15.25	140.64	275.7	1969	254.7	1819	5.0	195.2	2644	2944
C12	2301312-6	15.25	140.64	275.6	1969	251.4	1796	5.0	198.3	2783	3098
C12	2301313-4	15.27	141.40	276.3	1974	251.8	1799	5.5	196.5	3058	3402
C12	2301313-5	15.27	141.40	276.2	1973	250.9	1792	5.4	194.3	3058	3402

Filled by :Zhangchunting

Approved by : Shenyingsiang