



MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24 MM
Standard: ASTM A416/A416M-18
Production Licence No: XK 05-003-00098
Page No: 1/6
Inspection Date: JAN. 10TH, 2025
Invoice No: PCLPID2405C
Container No. GAOU2471973

Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
Q6	2412155-2	15.25	140.64	272.8	1949	250.2	1787	5.2	195.6	2831	3156
Q6	2412155-3	15.25	140.64	273.2	1951	250.6	1790	5.3	196.2	2832	3158
Q6	2412155-4	15.25	140.64	272.5	1946	249.8	1784	5.1	195.8	2832	3158
Q6	2412155-5	15.25	140.64	272.6	1947	249.4	1781	5.2	196.8	2829	3154
Q6	2412155-6	15.25	140.64	272.7	1948	249.2	1780	5.1	196.2	2948	3286
Q6	2412156-1	15.27	140.76	273.8	1956	255.8	1827	5.2	196.8	2840	3166
Q6	2412156-2	15.27	140.76	274.2	1959	254.7	1819	5.3	196.6	2840	3166
Q6	2412156-3	15.27	140.76	274.1	1958	255.0	1821	5.4	197.2	2841	3168
Q6	2412373-1	15.27	140.89	276.0	1971	253.4	1810	4.5	198.2	1879	2100

Quality objection: The buyer shall notify the seller in writing by email of any non-conformity of the quantity or quality of the subject matter within three months after arrival at the port. Where the buyer delays in giving notice beyond the prescribed time limit, the quantity or quality of the subject matter is deemed to be in conformity with the contract.

Filled by :Zhangchunting

Approved by : Shenyingsiang

