



MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 12.7MM
Standard: ASTM A416/A416M-15
Production Licence No: XK 05-003-00098
Page No: 1/1
Inspection Date: Dec.30th,2022
Invoice No: PCLPY2205C
Container No: ECMU2099902



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
6	2211355-3	12.80	99.36	193.7	1963	178.4	1807	4.9	199.1	3515	2756
6	2211355-5	12.80	99.36	193.9	1965	178.0	1803	5.2	199.2	3518	2758
6	2212359-3	12.70	97.71	194.0	1966	175.1	1774	5.0	191.9	3946	3092
6	2212359-4	12.70	97.71	194.8	1974	176.2	1785	4.9	192.2	3946	3092
6	2212152-7	12.71	97.96	194.4	1970	182.7	1851	5.2	195.1	4105	3216
6	2212153-1	12.73	98.09	195.0	1976	180.6	1830	4.8	198.9	4182	3276
6	2212153-7	12.73	98.09	192.8	1953	182.8	1852	5.0	195.8	3979	3118
6	2212154-7	12.72	97.71	188.5	1910	175.8	1781	5.0	193.5	3964	3106
6	2212155-1	12.75	98.47	195.4	1980	177.1	1794	5.2	196.5	4221	3306

Filled by :Zhangchunting

Approved by : Shenyingsiang