



QINGDAO GLOBAL OVERSEAS IMP&EXP CO., LTD

Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Liscence No: XK 05-003-00098
Page No: 5/6
Inspection Date: SEP.23, 2022
Invoice No: PCLPY2201C
Container No. ECMU2018515



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
5	2209376-3	15.28	140.89	275.9	1971	252.0	1800	5.4	191.7	2454	2738
5	2209376-7	15.28	140.89	275.4	1967	251.4	1796	5.3	192.6	2640	2944
5	2209139-2	15.32	141.15	280.2	2001	259.4	1853	5.1	196.1	2859	3188
5	2209379-1	15.32	141.66	281.9	2014	254.4	1817	5.3	193.6	2459	2744
5	2209379-3	15.32	141.66	281.2	2009	254.8	1820	5.1	194.0	2659	2966
5	2209380-2	15.32	141.40	277.4	1981	255.9	1828	5.0	195.6	2849	3176
5	2209139-4	15.32	141.15	278.3	1988	251.8	1799	5.2	192.5	2667	2974
5	2209140-1	15.27	141.02	280.9	2006	264.3	1888	5.2	198.1	2867	3196
5	2209140-2	15.27	141.02	280.7	2005	264.1	1886	5.1	197.9	2838	3164

Filled by :Zhangchunting

Approved by : Shenyingxiang