



QINGDAO GLOBAL OVERSEAS IMP&EXP CO., LTD

Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Licence No: XK 05-003-00098
Page No: 3/6
Inspection Date: SEP.23, 2022
Invoice No: PCLPY2201C
Container No. CMAU1487310



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
3	2209372-5	15.29	141.02	274.3	1959	255.9	1828	4.8	198.7	3016	3362
3	2209374-4	15.33	141.53	277.4	1981	255.8	1827	5.8	197.4	2656	2962
3	2209375-2	15.33	141.78	281.8	2013	256.7	1834	5.2	190.7	2894	3226
3	2209375-6	15.33	141.78	280.8	2006	258.3	1845	5.2	192.8	2899	3232
3	2209376-4	15.28	140.89	275.0	1964	250.2	1787	5.3	196.4	2452	2736
3	2209376-5	15.28	140.89	275.8	1970	250.8	1791	5.5	192.4	2449	2732
3	2209376-6	15.28	140.89	275.4	1967	251.3	1795	5.3	194.1	2449	2732
3	2209377-1	15.29	141.15	280.4	2003	260.8	1863	5.2	194.0	2652	2958
3	2209378-7	15.31	141.40	280.4	2003	260.6	1861	5.3	197.1	2742	3058

Filled by :Zhangchunting

Approved by : Shenyangxiang