



MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Lisence No: XK 05-003-00098
Page No: 11/12
Inspection Date: Jan.4th,2022
Invoice No: PCLPY2205C
Container No. APZU3374596



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
C11	2301303-2	15.27	140.89	275.0	1964	254.7	1819	5.0	192.0	2847	3168
C11	2301303-3	15.27	140.89	275.1	1965	252.8	1806	5.2	196.2	2848	3170
C11	2301303-4	15.27	140.89	275.4	1967	250.3	1788	5.6	199.5	2848	3170
C11	2301305-4	15.28	141.02	274.7	1962	254.0	1814	4.8	198.4	2859	3182
C11	2301305-5	15.28	141.02	273.6	1954	251.0	1793	5.2	198.1	2859	3182
C11	2301306-3	15.26	140.89	271.6	1940	251.4	1796	5.0	195.3	2448	2726
C11	2301306-4	15.26	140.89	271.4	1939	248.4	1774	5.0	197.1	2446	2724
C11	2301307-1	15.26	140.76	274.1	1958	258.4	1846	4.5	192.2	2848	3170
C11	2301309-6	15.27	140.76	272.8	1949	247.0	1764	5.2	196.9	2948	3280

Filled by :Zhangchunting

Approved by : Shenyingsiang