



**MILL TEST CERTIFICATE**

**Customer:** PRODALAM S.A.  
**Commodity:** PRESTRESSED CONCRETE STRAND  
**Nominal Diameter:** 15.24MM  
**Standard:** ASTM A416/A416M-15  
**Production Licence No:** XK 05-003-00098  
**Page No:** 2/12  
**Inspection Date:** OCT.21, 2022  
**Invoice No:** PCLPY2203C  
**Container No.** GESU1432765



Mark on Coil	Coil No.	Dia MM	Section Area (mm <sup>2</sup> )	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
J2	2210383-5	15.25	140.38	271.0	1936	250.4	1789	5.2	196.0	2628	2926
J2	2210385-3	15.24	140.64	269.8	1927	250.3	1788	5.0	196.0	2440	2718
J2	2210385-5	15.24	140.64	269.8	1927	250.2	1787	5.0	194.9	2440	2718
J2	2210385-6	15.24	140.64	269.9	1928	248.4	1774	5.2	198.3	2440	2718
J2	2210386-1	15.27	141.02	271.9	1942	247.2	1766	5.4	196.9	3051	3394
J2	2210386-2	15.27	141.02	272.8	1949	249.4	1781	5.2	194.1	2852	3174
J2	2210386-3	15.27	141.02	273.2	1951	248.2	1773	5.3	192.7	2852	3174
J2	2210386-4	15.27	141.02	274.1	1958	246.3	1759	5.4	194.1	2856	3178
J2	2210386-5	15.27	141.02	273.4	1953	247.6	1769	5.5	198.1	2856	3178

**Filled by :Zhangchunting**

**Approved by : Shenyingsiang**