



QINGDAO GLOBAL OVERSEAS IMP&EXP CO., LTD

Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Liscence No: XK 05-003-00098
Page No: 2/6
Inspection Date: SEP.23, 2022
Invoice No: PCLPY2201C
Container No. CMAU1395810



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
2	2209374-5	15.33	141.53	277.0	1979	254.8	1820	5.4	194.1	2458	2742
2	2209374-6	15.33	141.53	266.7	1905	246.8	1763	5.2	194.0	2816	3140
2	2209375-1	15.33	141.78	281.2	2009	258.9	1849	4.9	196.5	2859	3188
2	2209375-3	15.33	141.78	280.7	2005	255.9	1828	5.3	198.4	2858	3186
2	2209375-4	15.33	141.78	280.4	2003	251.6	1797	5.3	194.7	2856	3184
2	2209375-5	15.33	141.78	280.5	2004	256.7	1834	5.4	199.2	2859	3188
2	2209376-1	15.28	140.89	276.3	1974	255.9	1828	5.0	194.4	2449	2732
2	2209376-2	15.28	140.89	276.0	1971	253.6	1811	5.3	198.7	2452	2736
2	2209140-3	15.27	141.02	280.5	2004	263.9	1885	5.0	197.7	2636	2940

Filled by :Zhangchunting

Approved by : Shenyangxiang