




MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24 MM
Standard: ASTM A416/A416M-15
Production Licence No: XK 05-003-00098
Page No: 6/8
Inspection Date: APR.14TH,2024
Invoice No: PCLPY2402C
Container No. TGHU1689709



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
B18	2404348-1	15.24	140.51	271.8	1941	251.7	1798	5.0	194.3	3032	3380
B18	2404349-1	15.23	140.38	272.6	1947	249.1	1779	5.1	198.6	3027	3374
B18	2404352-2	15.26	140.51	273.0	1950	251.2	1794	5.2	197.1	2820	3144
B18	2404352-3	15.26	140.51	271.6	1940	250.6	1790	5.2	198.1	2832	3158
B18	2404352-4	15.26	140.51	272.4	1946	244.4	1746	5.3	191.8	2832	3158
B18	2404352-5	15.26	140.51	271.4	1939	245.3	1752	5.0	198.1	2629	2932
B18	2404352-7	15.26	140.51	273.8	1956	245.9	1756	5.7	195.3	2791	3112
B18	2404353-3	15.25	140.89	274.6	1961	249.8	1784	5.8	196.1	2432	2714
B18	2404353-4	15.25	140.89	273.7	1955	247.2	1766	5.6	193.4	2434	2716

Quality objection: The buyer shall notify the seller in writing by email of any non-conformity of the quantity or quality of the subject matter within three months after arrival at the port. Where the buyer delays in giving notice beyond the prescribed time limit, the quantity or quality of the subject matter is deemed to be in conformity with the contract.

Filed by :Zhangchunting

Approved by : Shenyingsiang