



**MILL TEST CERTIFICATE**

**Customer:** PRODALAM S.A.  
**Commodity:** PRESTRESSED CONCRETE STRAND  
**Nominal Diameter:** 15.24MM  
**Standard:** ASTM A416/A416M-15  
**Production Licence No:** XK 05-003-00098  
**Page No:** 13/14  
**Inspection Date:** FEB.5th,2022  
**Invoice No:** PCLPY2301C  
**Container No.** TCKU2383430



Mark on Coil	Coil No.	Dia MM	Section Area (mm <sup>2</sup> )	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
B15	2302514-5	15.26	140.76	270.0	1929	251.0	1793	4.8	197.0	2446	2724
B15	2302309-1	15.27	141.02	272.9	1949	255.2	1823	5.5	191.7	2841	3162
B15	2302309-2	15.27	141.02	272.8	1949	254.0	1814	5.4	192.4	2839	3160
B15	2302309-3	15.27	141.02	273.0	1950	250.4	1789	5.2	194.1	2841	3162
B15	2302309-4	15.27	141.02	273.1	1951	251.3	1795	5.7	197.4	2921	3250
B15	2302309-5	15.27	141.02	273.4	1953	251.7	1798	5.2	192.5	2843	3164
B15	2302514-6	15.26	140.76	269.8	1927	251.0	1793	5.2	193.6	2639	2938
B15	2302515-4	15.28	141.02	272.5	1946	257.1	1836	5.3	191.5	2839	3160
B15	2302516-5	15.28	140.89	273.7	1955	253.9	1814	5.0	195.7	2643	2942

Filed by :Zhangchunting

Approved by : Shenyingsiang