



QINGDAO GLOBAL OVERSEAS IMP&EXP CO., LTD

Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Liscence No: XK 05-003-00098
Page No: 4/6
Inspection Date: SEP.23, 2022
Invoice No: PCLPY2201C
Container No. CMAU1867496



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
4	2209377-2	15.29	141.15	280.5	2004	259.4	1853	5.40	192.0	2650	2956
4	2209377-3	15.29	141.15	280.3	2002	260.1	1858	5.30	194.7	2650	2956
4	2209377-4	15.29	141.15	280.4	2003	259.7	1855	5.00	198.1	2652	2958
4	2209377-5	15.29	141.15	280.0	2000	254.8	1820	5.10	196.4	2649	2954
4	2209378-2	15.31	141.40	281.6	2011	258.7	1848	5.30	198.7	2445	2728
4	2209139-3	15.32	141.15	279.4	1996	260.7	1862	5.00	198.7	2659	2966
4	2209379-7	15.32	141.66	278.4	1989	251.1	1794	5.20	193.1	2485	2772
4	2209380-1	15.32	141.40	277.2	1989	256.1	1829	5.10	195.4	3061	3412
4	2209139-5	15.32	141.15	278.5	1989	252.0	1800	5.10	192.7	2921	3256

Filled by :Zhangchunting

Approved by : Shenyingxiang