



MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24 MM
Standard: ASTM A416/A416M-15
Production Licence No: XK 05-003-00098
Page No: 6/12
Inspection Date: Jun.22th,2023
Invoice No: PCLPID2305C
Container No. MSMU1833899



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
A6	2306402-1	15.25	140.76	271.4	1939	248.6	1776	5.3	199.4	2753	3064
A6	2306402-2	15.25	140.76	271.2	1937	248.4	1774	5.2	198.6	2756	3068
A6	2306402-4	15.25	140.76	270.4	1931	242.9	1735	5.1	191.0	3034	3376
A6	2306402-5	15.25	140.76	270.6	1933	244.3	1745	5.0	194.7	3027	3368
A6	2306404-1	15.22	140.25	274.2	1959	250.2	1787	5.2	198.9	2435	2712
A6	2306404-2	15.22	140.25	274.0	1957	250.0	1786	5.1	195.6	2435	2712
A6	2306404-3	15.22	140.25	273.8	1956	249.8	1784	5.0	194.1	2435	2712
A6	2306404-4	15.22	140.25	272.9	1949	243.8	1741	5.2	191.0	2435	2712
A6	2306404-5	15.22	140.25	272.7	1948	243.6	1740	5.1	195.3	2436	2713

Filled by :Zhangchunting

Approved by : Shenyingsiang