



MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Licence No: XK 05-003-00098
Page No: 1/14
Inspection Date: FEB.5th,2022
Invoice No: PCLPY2301C
Container No. FSCU3516197



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
B3	2302503-4	15.25	140.64	272.6	1947	255.5	1825	4.7	198.7	2830	3150
B3	2302503-5	15.25	140.64	272.0	1943	255.3	1824	4.6	198.2	2830	3150
B3	2302503-6	15.25	140.64	271.5	1939	254.8	1820	4.5	197.5	2964	3298
B3	2302504-1	15.24	140.51	273.0	1950	253.0	1807	5.2	196.5	2856	3178
B3	2302504-2	15.24	140.51	272.8	1949	252.8	1806	5.1	196.7	2738	3048
B3	2302504-4	15.24	140.51	270.6	1933	251.7	1798	4.5	197.5	2899	3226
B3	2302504-5	15.24	140.51	270.4	1931	251.5	1796	4.6	197.0	2877	3202
B3	2302507-7	15.26	140.64	269.8	1927	252.6	1804	5.2	197.2	2475	2756
B3	2301343-1	15.34	141.91	272.7	1948	251.0	1793	5.2	198.1	2473	2754

Filed by :Zhangchunting

Approved by : Shenyingsiang