




MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24 MM
Standard: ASTM A416/A416M-15
Production Licence No: XK 05-003-00098
Page No: 2/8
Inspection Date: APR.14TH,2024
Invoice No: PCLPY2402C
Container No. MSNU2068397



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
B14	2404342-2	15.26	140.89	269.1	1922	244.0	1743	5.4	195.4	2440	2722
B14	2404342-3	15.26	140.89	269.9	1928	245.6	1754	5.4	195.0	2631	2934
B14	2404342-4	15.26	140.89	269.5	1925	247.0	1764	5.2	196.4	2553	2848
B14	2404343-7	15.28	141.40	271.0	1936	250.7	1791	5.2	194.9	2726	3040
B14	2404344-1	15.24	140.38	268.7	1919	250.4	1789	5.0	191.2	3023	3370
B14	2404344-3	15.24	140.38	268.0	1914	247.9	1771	5.1	194.1	2818	3142
B14	2404344-4	15.24	140.38	267.8	1913	243.6	1740	5.0	192.0	2818	3142
B14	2404344-5	15.24	140.38	268.0	1914	247.0	1764	5.0	191.4	2818	3142
B14	2404344-6	15.24	140.38	268.4	1917	246.4	1760	5.2	196.0	2959	3298

Quality objection: The buyer shall notify the seller in writing by email of any non-conformity of the quantity or quality of the subject matter within three months after arrival at the port. Where the buyer delays in giving notice beyond the prescribed time limit, the quantity or quality of the subject matter is deemed to be in conformity with the contract.

Filed by :Zhangchunting

Approved by : Shenyingsiang