



QINGDAO GLOBAL OVERSEAS IMP&EXP CO., LTD

Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Licence No: XK 05-003-00098
Page No: 3/8
Inspection Date: OCT.06, 2022
Invoice No: PCLPY2202C
Container No. ECMU1841391



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
B3	2210306-5	15.34	142.04	275.3	1966	251.7	1798	5.5	196.2	2470	2756
B3	2210306-6	15.34	142.04	275.8	1970	252.0	1800	5.2	195.4	2472	2758
B3	2210307-3	15.30	141.40	274.5	1961	258.4	1846	5.0	194.0	2856	3184
B3	2210307-4	15.30	141.40	275.0	1964	255.1	1822	5.2	191.2	2856	3184
B3	2210307-5	15.30	141.40	275.2	1966	254.9	1821	5.3	191.4	2858	3186
B3	2210308-1	15.32	141.53	273.9	1956	255.1	1822	5.1	191.5	2865	3194
B3	2210308-2	15.32	141.53	274.1	1958	254.9	1821	5.2	191.3	2665	2972
B3	2210308-5	15.32	141.53	275.9	1971	249.6	1783	5.2	191.7	3074	3426
B3	2210309-1	15.30	141.40	275.8	1970	252.1	1801	5.3	191.5	2458	2742

Filed by :Zhangchunting

Approved by : Shenyingxiang