



MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Licence No: XK 05-003-00098
Page No: 5/14
Inspection Date: FEB.5th,2022
Invoice No: PCLPY2301C
Container No. CXDU2271954



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
B7	2301522-2	15.26	140.64	270.1	1929	251.7	1798	5.0	198.3	2832	3152
B7	2301522-3	15.26	140.64	271.4	1939	252.4	1803	5.2	191.4	2838	3158
B7	2302505-1	15.25	140.64	272.0	1943	256.8	1834	5.2	199.1	2832	3152
B7	2302505-2	15.25	140.64	273.0	1950	253.6	1811	5.0	198.8	2830	3150
B7	2302505-3	15.25	140.64	271.4	1939	252.7	1805	5.2	195.3	2834	3154
B7	2302505-4	15.25	140.64	273.4	1953	258.2	1844	4.5	196.5	2832	3152
B7	2302507-3	15.26	140.64	270.6	1933	252.7	1805	4.6	194.1	2635	2934
B7	2302507-4	15.26	140.64	269.9	1928	251.4	1796	5.0	190.6	2635	2934
B7	2302507-5	15.26	140.64	270.1	1929	250.3	1788	5.2	192.6	2635	2934

Filed by :Zhangchunting

Approved by : Shenyingsiang