



MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Lisence No: XK 05-003-00098
Page No: 2/12
Inspection Date: Jan.4th,2022
Invoice No: PCLPY2205C
Container No. CMAU1622240



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
C2	2212374-6	15.27	140.89	271.4	1939	250.6	1790	5.0	192.1	2933	3264
C2	2212375-1	15.30	140.51	273.1	1951	257.8	1841	4.5	195.8	3047	3390
C2	2212377-1	15.27	143.95	271.6	1940	249.5	1782	5.1	192.2	3051	3394
C2	2212378-2	15.28	141.02	272.8	1949	251.0	1793	5.0	195.3	2850	3172
C2	2212378-3	15.28	141.02	272.6	1947	250.7	1791	5.4	198.1	2850	3172
C2	2212378-4	15.28	141.02	274.3	1959	249.1	1779	5.4	190.9	2850	3172
C2	2212381-1	15.25	140.64	272.3	1945	253.5	1811	4.7	198.1	2446	2724
C2	2212381-2	15.25	140.64	272.5	1946	252.0	1800	4.8	197.5	2446	2724
C2	2212381-3	15.25	140.64	272.7	1948	250.1	1786	4.9	196.5	2444	2722

Filed by :Zhangchunting

Approved by : Shenyingxiang