



MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Lisence No: XK 05-003-00098
Page No: 9/12
Inspection Date: Jan.4th,2022
Invoice No: PCLPY2205C
Container No. ECMU2097303



| Mark on Coil | Coil No. | Dia MM | Section Area (mm ²) | Breaking Load (kN) | Tensile Strength MPA | 1%Extension Yield Load (kN) | Yield Strength MPA | Elongation (%) | Modules of Elasticity GPA | Length Approx. Meter | Coil Weight KGS |
|--------------|-----------|--------|---------------------------------|--------------------|----------------------|-----------------------------|--------------------|----------------|---------------------------|----------------------|-----------------|
| C9 | 2301303-5 | 15.27 | 140.89 | 275.3 | 1966 | 252.6 | 1804 | 5.5 | 197.3 | 2850 | 3172 |
| C9 | 2301303-6 | 15.27 | 140.89 | 275.0 | 1964 | 251.4 | 1796 | 5.2 | 194.7 | 2955 | 3288 |
| C9 | 2301304-1 | 15.26 | 140.76 | 276.6 | 1976 | 256.9 | 1835 | 5.2 | 195.6 | 2839 | 3160 |
| C9 | 2301304-2 | 15.26 | 140.76 | 276.4 | 1974 | 257.9 | 1842 | 5.4 | 197.2 | 2641 | 2940 |
| C9 | 2301304-3 | 15.26 | 140.76 | 276.2 | 1973 | 256.3 | 1831 | 5.5 | 199.5 | 2643 | 2942 |
| C9 | 2301304-4 | 15.26 | 140.76 | 276.1 | 1972 | 258.4 | 1846 | 5.7 | 192.5 | 2641 | 2940 |
| C9 | 2301304-5 | 15.26 | 140.76 | 276.5 | 1975 | 256.2 | 1830 | 5.6 | 194.1 | 2643 | 2942 |
| C9 | 2301304-6 | 15.26 | 140.76 | 276.3 | 1974 | 255.9 | 1828 | 5.4 | 194.6 | 2928 | 3258 |
| C9 | 2301305-1 | 15.28 | 141.02 | 275.5 | 1968 | 258.3 | 1845 | 5.0 | 192.9 | 2791 | 3106 |

Filled by :Zhangchunting

Approved by : Shenyingsiang