

MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24 MM
Standard: ASTM A416/A416M-15
Production Licence No: XK 05-003-00098
Page No: 6/6
Inspection Date: JAN. 10TH, 2025
Invoice No: PCLPID2405C
Container No. MSBU1213390

Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
Q13	2412328-3	15.26	141.02	274.4	1960	249.2	1780	5.6	196.7	1914	2138
Q13	2412141-1	15.29	141.78	271.2	1937	254.8	1820	5.1	198.6	2822	3146
Q13	2412143-5	15.23	140.38	271.4	1939	246.2	1759	5.4	195.8	2816	3140
Q13	2412144-6	15.25	140.64	273.9	1956	251.4	1796	5.4	196.7	2840	3166
Q13	2412359-6	15.27	141.40	268.1	1915	245.1	1751	5.2	195.3	2917	3252
Q13	2412361-5	15.27	141.15	272.6	1947	246.5	1761	5.3	196.8	2847	3174
Q13	2412361-7	15.27	141.15	271.8	1941	246.2	1759	5.1	196.0	2868	3198
Q13	2412151-5	15.26	141.15	274.8	1963	248.8	1777	5.1	197.2	2841	3168
Q13	2412373-5	15.27	140.89	271.4	1939	244.8	1749	4.9	196.2	2991	3334

Quality objection: The buyer shall notify the seller in writing by email of any non-conformity of the quantity or quality of the subject matter within three months after arrival at the port. Where the buyer delays in giving notice beyond the prescribed time limit, the quantity or quality of the subject matter is deemed to be in conformity with the contract.

Filled by :Zhangchunting

Approved by : Shenyingsiang