

MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24 MM
Standard: ASTM A416/A416M-15
Production Liscence No: XK 05-003-00098
Page No: 3/4
Inspection Date: SEP.10TH,2024
Invoice No: PCLPID2403C
Container No. MSBU3058740

Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
6	2409322-2	15.25	140.76	270.4	1931	244.8	1749	5.4	196.2	2643	2948
6	2409330-2	15.27	140.89	270.9	1935	250.7	1791	5.6	194.4	2906	3240
6	2409330-3	15.27	140.89	268.9	1921	248.6	1776	5.0	195.7	2906	3240
6	2409331-6	15.29	141.27	270.1	1929	249.8	1784	4.9	197.6	2935	3272
6	2409332-6	15.29	141.53	271.4	1939	245.0	1750	5.2	198.9	2283	2548
6	2409117-6	15.28	141.53	270.2	1930	248.0	1771	5.0	192.8	2948	3286
6	2409118-6	15.27	141.27	272.0	1943	250.7	1791	5.2	198.5	2951	3290
6	2409122-1	15.27	141.15	273.2	1951	254.2	1816	5.8	196.7	2746	3062
6	2409127-6	15.26	141.02	274.3	1959	257.4	1839	5.0	199.8	2477	2764

Quality objection: The buyer shall notify the seller in writing by email of any non-conformity of the quantity or quality of the subject matter within three months after arrival at the port. Where the buyer delays in giving notice beyond the prescribed time limit, the quantity or quality of the subject matter is deemed to be in conformity with the contract.

Filled by :Zhangchunting

Approved by : Shenyingsiang