



**MILL TEST CERTIFICATE**

**Customer:** PRODALAM S.A.  
**Commodity:** PRESTRESSED CONCRETE STRAND  
**Nominal Diameter:** 15.24 MM  
**Standard:** ASTM A416/A416M-18  
**Production Licence No:** XK 05-003-00098  
**Page No:** 1/4  
**Inspection Date:** SEP.10TH,2024  
**Invoice No:** PCLPID2403C  
**Container No.** TLLU2340243



Mark on Coil	Coil No.	Dia MM	Section Area (mm <sup>2</sup> )	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
4	2409319-2	15.26	140.89	267.2	1909	246.2	1759	5.4	196.2	2841	3168
4	2409319-3	15.26	140.89	267.5	1911	245.8	1756	5.2	198.1	2841	3168
4	2409319-4	15.26	140.89	267.6	1911	245.4	1753	5.7	190.4	2841	3168
4	2409319-5	15.26	140.89	267.0	1907	247.2	1766	5.4	191.3	2840	3166
4	2409320-3	15.29	141.40	268.6	1919	250.1	1786	5.1	194.8	2858	3186
4	2409320-4	15.29	141.40	269.8	1927	245.3	1752	5.3	198.4	2856	3184
4	2409320-5	15.29	141.40	268.3	1916	247.8	1770	5.2	195.7	2859	3188
4	2409323-6	15.25	140.76	269.0	1921	247.2	1766	5.1	196.7	2326	2596
4	2409116-4	15.28	141.66	271.4	1939	255.4	1824	4.9	197.3	2459	2744

Quality objection: The buyer shall notify the seller in writing by email of any non-conformity of the quantity or quality of the subject matter within three months after arrival at the port. Where the buyer delays in giving notice beyond the prescribed time limit, the quantity or quality of the subject matter is deemed to be in conformity with the contract.

**Filled by :Zhangchunting**

**Approved by : Shenyingsiang**