



QINGDAO GLOBAL OVERSEAS IMP&EXP CO., LTD

Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Lisence No: XK 05-003-00098
Page No: 6/6
Inspection Date: SEP.23, 2022
Invoice No: PCLPY2201C
Container No. ECMU2121992



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
6	2209378-1	15.31	141.40	281.8	2013	259.7	1855	5.2	191.0	2241	2502
6	2209139-1	15.32	141.15	279.8	1999	262.4	1874	5.1	195.9	2865	3194
6	2209379-5	15.32	141.66	280.6	2004	264.4	1889	4.8	198.3	2659	2966
6	2209379-6	15.32	141.66	280.8	2006	264.2	1887	4.9	198.1	2659	2966
6	2209380-3	15.32	141.40	277.6	1983	255.7	1826	5.1	195.8	2850	3178
6	2209380-4	15.32	141.40	277.7	1984	254.1	1815	5.2	198.5	2850	3178
6	2209140-4	15.27	141.02	279.9	1999	258.0	1843	5.1	196.5	2638	2942
6	2209140-5	15.27	141.02	280.1	2001	258.2	1844	5.0	196.7	2638	2942
6	2209140-6	15.27	141.02	280.3	2002	258.4	1846	5.1	196.9	2805	3128

Filled by :Zhangchunting

Approved by : Shenyingxiang