



MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Lisence No: XK 05-003-00098
Page No: 4/12
Inspection Date: Jan.4th,2022
Invoice No: PCLPY2205C
Container No. GESU1372666



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
C4	2212376-4	15.26	140.76	273.8	1956	250.6	1790	4.6	196.3	3051	3394
C4	2212378-1	15.28	141.02	271.4	1939	250.3	1788	5.5	198.1	3045	3388
C4	2212378-6	15.28	141.02	270.3	1931	250.3	1788	5.5	198.1	2755	3066
C4	2212379-1	15.26	140.64	271.6	1940	249.8	1784	5.2	191.1	3043	3386
C4	2212379-5	15.26	140.64	271.6	1940	251.6	1797	5.2	195.3	2838	3158
C4	2212380-3	15.25	140.51	271.4	1939	249.8	1784	5.2	198.1	2838	3158
C4	2212381-4	15.25	140.64	273.0	1950	248.4	1774	5.2	191.6	2442	2720
C4	2212381-5	15.25	140.64	273.2	1951	248.6	1776	5.1	195.0	2442	2720
C4	2212381-6	15.25	140.64	273.3	1952	251.2	1794	5.0	197.5	2444	2722

Filled by :Zhangchunting

Approved by : Shenyingsiang