




QINGDAO GLOBAL OVERSEAS IMP&EXP CO., LTD

Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24 MM
Standard: ASTM A416/A416M-15
Production Liscence No: XK 05-003-00098
Page No: 5/12
Inspection Date: Jun.22th,2023
Invoice No: PCLPID2305C
Container No. MEDU2456353



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
A5	2306552-3	15.27	141.27	275.0	1964	252.4	1803	5.4	196.5	2480	2762
A5	2306552-4	15.27	141.27	275.3	1966	250.9	1792	5.5	196.2	2480	2762
A5	2306552-5	15.27	141.27	275.4	1967	251.6	1797	5.3	198.5	2478	2760
A5	2306552-6	15.27	141.27	275.1	1965	253.4	1810	5.5	197.3	2480	2762
A5	2306552-7	15.27	141.27	275.4	1967	251.7	1798	5.3	192.5	2361	2630
A5	2306553-3	15.25	140.38	276.2	1973	250.9	1792	5.4	196.2	2874	3198
A5	2306553-5	15.25	140.38	277.0	1979	253.1	1808	5.3	198.4	2874	3198
A5	2306554-4	15.23	139.62	269.0	1921	245.1	1751	5.2	196.2	2861	3184
A5	2306554-5	15.23	139.62	269.4	1924	246.8	1763	5.2	191.4	2861	3184

Filled by :Zhangchunting

Approved by : Shenyingsiang