


Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

### MILL TEST CERTIFICATE

Customer: **PRODALAM S.A.**  
Commodity: **PRESTRESSED CONCRETE STRAND**  
Nominal Diameter: **15.24 MM**  
Standard: **ASTM A416/A416M-15**  
Production Licence No: **XK 05-003-00098**  
Page No: **3/8**  
Inspection Date: **APR.14TH,2024**  
Invoice No: **PCLPY2402C**  
Container No. **TRHU1192437**



Mark on Coil	Coil No.	Dia MM	Section Area (mm <sup>2</sup> )	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
B15	2404349-4	15.23	140.38	270.6	1933	248.0	1771	5.3	196.0	2827	3152
B15	2404349-5	15.23	140.38	271.1	1936	249.2	1780	5.2	194.1	2829	3154
B15	2404350-2	15.24	140.51	270.1	1929	253.0	1807	5.2	191.6	3034	3382
B15	2404350-3	15.24	140.51	272.0	1943	251.4	1796	5.1	195.1	2932	3268
B15	2404350-4	15.24	140.51	271.6	1940	252.8	1806	5.3	198.8	2614	2916
B15	2404350-5	15.24	140.51	271.0	1936	249.8	1784	5.2	193.4	2829	3154
B15	2404350-6	15.24	140.51	270.1	1929	245.7	1755	4.7	190.1	2831	3156
B15	2404351-1	15.24	140.64	272.6	1947	253.5	1811	4.7	195.8	2434	2716
B15	2404351-2	15.24	140.64	271.0	1936	251.4	1796	5.2	191.1	2429	2710

Quality objection: The buyer shall notify the seller in writing by email of any non-conformity of the quantity or quality of the subject matter within three months after arrival at the port. Where the buyer delays in giving notice beyond the prescribed time limit, the quantity or quality of the subject matter is deemed to be in conformity with the contract.

Filed by :Zhangchunting

Approved by : Shenyangxiang