



**MILL TEST CERTIFICATE**

**Customer:** PRODALAM S.A.  
**Commodity:** PRESTRESSED CONCRETE STRAND  
**Nominal Diameter:** 15.24MM  
**Standard:** ASTM A416/A416M-15  
**Production Licence No:** XK 05-003-00098  
**Page No:** 9/12  
**Inspection Date:** OCT.21, 2022  
**Invoice No:** PCLPY2203C  
**Container No.** GESU1278650



Mark on Coil	Coil No.	Dia MM	Section Area (mm <sup>2</sup> )	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
J9	2210524-5	15.24	140.89	272.1	1944	253.7	1812	5.5	195.7	2464	2744
J9	2210527-1	15.28	141.27	274.7	1962	259.0	1850	4.9	194.6	2451	2730
J9	2210527-5	15.28	141.27	275.4	1967	251.4	1796	5.3	197.0	2850	3172
J9	2210528-1	15.25	141.02	272.6	1947	254.7	1819	5.1	194.0	2847	3168
J9	2210529-3	15.25	140.51	274.1	1958	252.6	1804	5.1	196.4	2832	3152
J9	2210529-4	15.25	140.51	274.3	1959	250.7	1791	5.3	196.1	2838	3158
J9	2210529-5	15.25	140.51	274.4	1960	251.2	1794	5.1	198.5	2834	3154
J9	2210530-2	15.24	140.51	275.4	1967	252.8	1806	5.1	197.2	2866	3190
J9	2210398-1	15.25	140.64	272.0	1943	254.6	1819	5.6	191.4	2442	2720

**Filed by :Zhangchunting**

**Approved by : Shenyingxiang**