


Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24 MM
Standard: ASTM A416/A416M-18
Production Liscence No: XK 05-003-00098
Page No: 4/8
Inspection Date: Aug.21th,2023
Invoice No: PCLPID2307C
Container No. UETU2168778



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
A16	2308150-4	15.32	141.78	271.0	1936	247.6	1769	5.1	197.7	2829	3154
A16	2308150-5	15.32	141.78	270.9	1935	251.7	1798	5.0	194.1	2838	3164
A16	2308151-1	15.32	141.91	272.7	1948	256.4	1831	4.7	194.2	2668	2976
A16	2308151-3	15.32	141.91	272.6	1947	255.9	1828	4.9	192.7	2589	2888
A16	2308151-4	15.32	141.91	272.1	1944	256.4	1831	5.1	197.9	2467	2752
A16	2308152-1	15.31	141.66	271.0	1936	254.2	1816	5.0	196.0	2831	3156
A16	2308375-2	15.30	141.40	266.0	1900	251.2	1794	5.1	190.7	2856	3184
A16	2308375-5	15.30	141.40	266.2	1901	250.4	1789	4.9	198.2	2859	3188
A16	2308376-6	15.28	141.02	266.0	1900	247.0	1764	5.2	194.8	2933	3270

Quality objection: The buyer shall notify the seller in writing by email of any non-conformity of the quantity or quality of the subject matter within three months after arrival at the port. Where the buyer delays in giving notice beyond the prescribed time limit, the quantity or quality of the subject matter is deemed to be in conformity with the contract.

Filled by :Zhangchunting

Approved by : Shenyingxiang