



QINGDAO GLOBAL OVERSEAS IMP&EXP CO., LTD

Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24 MM
Standard: ASTM A416/A416M-15
Production Liscence No: XK 05-003-00098
Page No: 11/12
Inspection Date: Jun.22th,2023
Invoice No: PCLPID2305C
Container No. TCKU3962349

Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
A11	2306390-5	15.23	140.00	272.0	1943	252.1	1801	5.2	196.3	2857	3180
A11	2306390-6	15.23	140.00	272.4	1946	253.6	1811	5.2	198.7	2884	3210
A11	2306391-3	15.24	139.87	273.7	1955	250.6	1790	5.2	196.5	2861	3184
A11	2306151-3	15.26	140.13	273.9	1956	252.6	1804	5.0	192.5	2838	3158
A11	2306548-5	15.26	140.89	274.0	1957	250.4	1789	5.2	193.1	2471	2752
A11	2306548-6	15.26	140.89	272.6	1947	252.7	1805	5.3	195.1	2471	2752
A11	2306549-1	15.26	141.02	271.8	1941	256.0	1829	5.0	193.8	2471	2752
A11	2306549-2	15.26	141.02	272.0	1943	251.0	1793	5.0	191.3	2473	2754
A11	2306549-6	15.26	141.02	270.8	1934	255.1	1822	5.0	193.8	2477	2758

Filled by :Zhangchunting

Approved by : Shenyangxiang