




Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24 MM
Standard: ASTM A416/A416M-18
Production Licence No: XK 05-003-00098
Page No: 6/8
Inspection Date: Aug.21th,2023
Invoice No: PCLPID2307C
Container No. APZU3757682



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
A15	2308405-6	15.30	141.78	275.9	1971	251.9	1799	5.0	199.6	2921	3256
A15	2308407-2	15.25	140.76	272.3	1945	247.4	1767	4.8	194.8	2838	3164
A15	2308407-3	15.25	140.76	272.5	1946	247.6	1769	4.7	196.0	2834	3160
A15	2308407-6	15.25	140.76	272.1	1944	248.1	1772	5.0	194.3	2919	3254
A15	2308408-5	15.23	140.51	271.1	1936	248.7	1776	5.2	195.7	2441	2724
A15	2308408-6	15.23	140.51	271.3	1938	248.5	1775	5.0	197.2	2441	2724
A15	2308408-7	15.23	140.51	272.7	1948	245.9	1756	5.1	198.6	2805	3128
A15	2308411-3	15.29	141.02	273.0	1950	251.8	1799	5.0	192.9	2836	3162
A15	2308411-4	15.29	141.02	271.9	1942	252.9	1806	5.1	194.3	2836	3162

Quality objection: The buyer shall notify the seller in writing by email of any non-conformity of the quantity or quality of the subject matter within three months after arrival at the port. Where the buyer delays in giving notice beyond the prescribed time limit, the quantity or quality of the subject matter is deemed to be in conformity with the contract.

Filed by :Zhangchunting

Approved by : Shenyingxiang