



QINGDAO GLOBAL OVERSEAS IMP&EXP CO., LTD

Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

MILL TEST CERTIFICATE

Customer:

PRODALAM S.A.

Commodity:

PRESTRESSED CONCRETE STRAND

Nominal Diameter:

15.24MM

Standard:

ASTM A416/A416M-15

Production Liscence No:

XK 05-003-00098

Page No:

4/4

Inspection Date:

MAR.28TH,2023

Invoice No:

PCLPID2304C-1

Container No.

CAAU2115538



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
B11	2303408-6	15.26	140.89	270.1	1929	250.1	1786	5.5	198.3	2926	3262
B11	2303409-6	15.26	141.02	271.0	1936	249.3	1781	5.2	195.3	2966	3306
B11	2303410-6	15.22	140.13	268.0	1914	250.1	1786	5.2	196.5	2951	3290
B11	2303411-4	15.29	141.27	269.7	1926	247.6	1769	5.1	194.3	2445	2728
B11	2303412-2	15.31	141.66	273.2	1951	250.2	1787	5.2	194.6	2856	3184
B11	2303412-3	15.31	141.66	272.6	1947	251.4	1796	5.1	192.7	2652	2958
B11	2303412-4	15.31	141.66	271.7	1941	249.3	1781	5.1	198.2	2652	2958
B11	2303412-5	15.31	141.66	272.4	1946	250.6	1790	5.0	191.8	2650	2956
B11	2303413-4	15.24	140.38	269.9	1928	249.5	1782	5.9	191.6	2820	3144

Filled by :Zhangchunting

Approved by : Shenyangxiang