



QINGDAO GLOBAL OVERSEAS IMP&EXP CO., LTD

Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Licence No: XK 05-003-00098
Page No: 4/8
Inspection Date: OCT.06, 2022
Invoice No: PCLPY2202C
Container No. APZU3882534



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
B4	2209174-6	15.28	141.27	272.7	1948	253.4	1810	5.3	192.6	3058	3408
B4	2210309-2	15.30	141.40	275.6	1969	250.9	1792	5.2	191.7	2461	2746
B4	2210309-3	15.30	141.40	275.4	1967	250.7	1791	5.1	191.9	2461	2746
B4	2210309-4	15.30	141.40	274.4	1960	245.1	1751	5.2	198.4	2459	2744
B4	2210309-5	15.30	141.40	274.2	1959	245.3	1752	5.1	198.2	2461	2746
B4	2210310-2	15.32	141.66	275.3	1966	248.3	1774	5.4	191.7	2870	3200
B4	2210310-4	15.32	141.66	275.4	1967	246.4	1760	5.5	192.0	2874	3204
B4	2210310-5	15.32	141.66	275.2	1966	246.2	1759	5.3	192.2	2868	3198
B4	2210108-3	15.32	141.78	277.0	1966	259.3	1852	5.0	196.4	3065	3416

Filed by :Zhangchunting

Approved by : Shenyangxiang