



MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Liscence No: XK 05-003-00098
Page No: 8/8
Inspection Date: MAR.5th,2023
Invoice No: PCLPID2302C
Container No. CMAU0628563



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPa	Length Approx. Meter	Coil Weight KGS
J9	2302182-5	15.24	140.51	270.0	1929	250.6	1790	5.0	192.7	2444	2722
J9	2302182-6	15.24	140.51	269.8	1927	250.2	1787	4.9	192.5	2444	2722
J9	2302183-6	15.26	140.89	270.1	1929	251.4	1796	5.1	196.4	2650	2950
J9	2302185-1	15.27	140.89	272.3	1945	256.2	1830	4.8	192.3	3058	3402
J9	2302185-5	15.27	140.89	271.4	1939	252.1	1801	5.0	194.4	2857	3180
J9	2302186-2	15.28	141.02	272.7	1948	254.6	1819	5.1	192.1	2866	3190
J9	2302186-3	15.28	141.02	271.9	1942	251.8	1799	4.9	196.4	2866	3190
J9	2302186-4	15.28	141.02	270.3	1931	250.9	1792	5.4	196.7	2866	3190
J9	2302186-5	15.28	141.02	270.6	1933	250.4	1789	5.2	196.8	2866	3190

Filed by :Zhangchunting

Approved by : Shenyingsiang