

Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24 MM
Standard: ASTM A416/A416M-15
Production Lisence No: XK 05-003-00098
Page No: 4/4
Inspection Date: SEP.22ND,2024
Invoice No: PCLPID2403C-1
Container No. SEGU1070423

Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
11	2409352-1	15.24	140.51	268.7	1919	248.1	1772	4.9	199.7	2472	2758
11	2409357-1	15.27	141.02	267.6	1911	252.1	1801	4.8	192.9	2881	3212
11	2409357-3	15.27	141.02	269.8	1927	245.2	1751	5.3	194.6	2443	2726
11	2409357-5	15.27	141.02	269.4	1924	243.6	1740	5.1	195.1	2604	2904
11	2409358-1	15.24	140.51	270.7	1934	252.1	1801	5.1	199.9	2867	3196
11	2409358-2	15.24	140.51	268.4	1917	247.7	1769	5.2	199.0	2867	3196
11	2409358-6	15.24	140.51	269.0	1921	246.8	1763	5.2	193.7	2960	3300
11	2409359-1	15.27	141.15	269.1	1922	246.2	1759	5.1		2876	3206
11	2409359-3	15.27	141.15	268.0	1914	246.7	1762	4.9		2632	2936

Quality objection: The buyer shall notify the seller in writing by email of any non-conformity of the quantity or quality of the subject matter within three months after arrival at the port. Where the buyer delays in giving notice beyond the prescribed time limit, the quantity or quality of the subject matter is deemed to be in conformity with the contract.

Filed by :Zhangchunting

Approved by : Shenyingxiang

