




MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Licence No: XK 05-003-00098
Page No: 3/14
Inspection Date: FEB.5th,2022
Invoice No: PCLPY2301C
Container No. MSDU1647265



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
B5	2301522-4	15.26	140.64	269.9	1928	246.4	1760	4.8	196.2	2836	3156
B5	2301522-5	15.26	140.64	268.1	1915	247.0	1764	5.1	193.6	2836	3156
B5	2302501-1	15.25	140.64	271.7	1941	250.2	1787	5.1	190.3	3025	3366
B5	2302501-2	15.25	140.64	271.9	1942	250.4	1789	5.0	190.5	2829	3148
B5	2302501-3	15.25	140.64	272.1	1944	250.6	1790	4.9	190.7	2825	3144
B5	2302501-4	15.25	140.64	272.7	1948	250.5	1789	5.1	198.1	2829	3148
B5	2302502-2	15.25	140.76	270.7	1934	250.7	1791	4.6	196.9	2863	3186
B5	2301343-4	15.34	141.91	273.4	1953	249.0	1779	5.1	193.6	2471	2752
B5	2301343-5	15.34	141.91	273.0	1950	253.8	1813	5.5	193.6	2473	2754

Filed by :Zhangchunting

Approved by : Shenyingsiang