



MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Licence No: XK 05-003-00098
Page No: 6/12
Inspection Date: Jan.4th,2022
Invoice No: PCLPY2205C
Container No. CMAU1962322



| Mark on Coil | Coil No. | Dia MM | Section Area (mm ²) | Breaking Load (kN) | Tensile Strength MPA | 1%Extension Yield Load (kN) | Yield Strength MPA | Elongation (%) | Modules of Elasticity GPA | Length Approx. Meter | Coil Weight KGS |
|--------------|-----------|--------|---------------------------------|--------------------|----------------------|-----------------------------|--------------------|----------------|---------------------------|----------------------|-----------------|
| C6 | 2212380-5 | 15.25 | 140.51 | 270.7 | 1934 | 253.1 | 1808 | 5.0 | 198.4 | 2839 | 3160 |
| C6 | 2212382-6 | 15.28 | 140.89 | 275.4 | 1967 | 249.5 | 1782 | 5.0 | 194.2 | 2453 | 2732 |
| C6 | 2212383-1 | 15.25 | 140.51 | 274.4 | 1960 | 255.7 | 1826 | 5.0 | 193.6 | 3051 | 3394 |
| C6 | 2212383-2 | 15.25 | 140.51 | 273.9 | 1956 | 251.4 | 1796 | 5.0 | 192.1 | 2841 | 3162 |
| C6 | 2212383-3 | 15.25 | 140.51 | 272.7 | 1948 | 252.2 | 1801 | 4.9 | 196.5 | 2843 | 3164 |
| C6 | 2212383-4 | 15.25 | 140.51 | 272.0 | 1943 | 253.8 | 1813 | 4.6 | 197.2 | 3018 | 3358 |
| C6 | 2212383-6 | 15.25 | 140.51 | 272.4 | 1946 | 250.6 | 1790 | 5.0 | 194.9 | 2971 | 3306 |
| C6 | 2301301-1 | 15.25 | 140.51 | 276.3 | 1974 | 256.2 | 1830 | 5.1 | 197.2 | 2444 | 2722 |
| C6 | 2301301-2 | 15.25 | 140.51 | 274.1 | 1958 | 251.1 | 1794 | 5.2 | 198.8 | 2444 | 2722 |

Filled by :Zhangchunting

Approved by : Shenyingsiang