



MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Licence No: XK 05-003-00098
Page No: 7/12
Inspection Date: Jan.4th,2022
Invoice No: PCLPY2205C
Container No. SEGU1281350



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
C7	2301301-3	15.25	140.51	274.6	1961	252.0	1800	5.3	191.4	2442	2720
C7	2301301-4	15.25	140.51	273.5	1954	252.5	1804	4.5	194.9	2440	2718
C7	2301301-7	15.25	140.51	273.8	1956	251.6	1797	4.9	195.2	2717	3024
C7	2301102-1	15.25	140.64	275.0	1964	258.6	1847	4.6	197.7	3052	3396
C7	2301102-2	15.25	140.64	275.8	1970	254.4	1817	4.9	196.2	2845	3166
C7	2301102-3	15.25	140.64	276.4	1974	253.6	1811	4.8	194.5	2847	3168
C7	2301102-4	15.25	140.64	277.1	1979	255.9	1828	4.8	193.1	2847	3168
C7	2301102-5	15.25	140.64	276.8	1977	256.2	1830	4.9	197.8	2847	3168
C7	2301102-6	15.25	140.64	276.2	1973	258.6	1847	4.9	194.5	2888	3214

Filled by :Zhangchunting

Approved by : Shenyngxiang