



QINGDAO GLOBAL OVERSEAS IMP&EXP CO., LTD

Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Licence No: XK 05-003-00098
Page No: 1/8
Inspection Date: OCT.06, 2022
Invoice No: PCLPY2202C
Container No. APZU3961470



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
B1	2209430-2	15.29	141.53	273.2	1951	251.7	1798	5.0	191.2	2456	2740
B1	2209430-3	15.29	141.53	271.6	1940	253.8	1813	5.5	199.0	2454	2738
B1	2209430-4	15.29	141.53	273.6	1954	250.6	1790	5.3	194.8	2454	2738
B1	2210302-4	15.31	141.40	274.4	1960	251.6	1797	5.5	196.5	2856	3184
B1	2210304-2	15.31	141.53	274.8	1963	257.0	1836	5.3	190.6	2859	3188
B1	2210304-3	15.31	141.53	274.7	1962	256.2	1830	5.2	192.2	2859	3188
B1	2210304-4	15.31	141.53	275.0	1964	255.7	1826	5.4	198.7	2865	3194
B1	2210304-5	15.31	141.53	274.9	1964	253.8	1813	5.1	198.7	2865	3194
B1	2210305-2	15.31	141.53	277.0	1979	252.6	1804	5.1	198.6	2861	3190

Filed by :Zhangchunting

Approved by : Shenyingxiang