



MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Lisence No: XK 05-003-00098
Page No: 12/14
Inspection Date: FEB.5th,2022
Invoice No: PCLPY2301C
Container No. MSDU1607067



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
B14	2302306-4	15.23	140.51	272.1	1944	250.8	1791	4.9	197.8	2440	2718
B14	2302306-5	15.23	140.51	272.3	1945	250.6	1790	4.8	197.6	2440	2718
B14	2302515-1	15.28	141.02	271.0	1936	251.0	1793	5.5	195.3	2839	3160
B14	2302515-2	15.28	141.02	272.0	1943	252.6	1804	5.4	191.6	2839	3160
B14	2302515-3	15.28	141.02	272.8	1949	253.6	1811	5.3	194.1	2841	3162
B14	2302515-5	15.28	141.02	271.4	1939	253.8	1813	5.5	198.8	2704	3010
B14	2302516-1	15.28	140.89	274.2	1959	254.8	1820	5.4	197.6	3052	3396
B14	2302516-3	15.28	140.89	273.8	1956	252.7	1805	5.2	191.4	2881	3206
B14	2302516-4	15.28	140.89	273.5	1954	256.6	1833	5.1	192.3	2845	3166

Filed by :Zhangchunting

Approved by : Shenyingsiang