



MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Liscence No: XK 05-003-00098
Page No: 10/12
Inspection Date: Jan.4th,2022
Invoice No: PCLPY2205C
Container No. CMAU1813587



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
C10	2301302-1	15.27	140.76	273.5	1954	256.1	1829	4.7	196.1	2836	3156
C10	2301302-2	15.27	140.76	274.0	1957	254.6	1819	5.1	197.2	2841	3162
C10	2301302-3	15.27	140.76	274.0	1957	251.4	1796	5.1	197.5	2838	3158
C10	2301302-4	15.27	140.76	274.2	1959	250.6	1790	4.9	196.8	2839	3160
C10	2301302-5	15.27	140.76	274.3	1959	249.6	1783	5.0	191.4	2839	3160
C10	2301302-6	15.27	140.76	274.7	1962	252.8	1806	5.0	193.4	2903	3230
C10	2301303-1	15.27	140.89	274.9	1964	257.3	1838	4.7	198.3	3052	3396
C10	2301306-1	15.26	140.89	272.4	1946	251.7	1798	5.5	198.8	2448	2726
C10	2301306-2	15.26	140.89	272.8	1949	250.3	1788	5.2	191.6	2448	2726

Filled by :Zhangchunting

Approved by : Shenyingxiang