

Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24 MM
Standard: ASTM A416/A416M-18
Production Lisence No: XK 05-003-00098
Page No: 1/8
Inspection Date: APR.14TH,2024
Invoice No: PCLPY2402C
Container No. MSNU2068503

Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
B1	2402325-4	15.33	142.04	272.3	1945	247.5	1768	5.1	192.1	2672	2980
B1	2402329-3	15.35	142.29	273.2	1951	249.7	1784	5.5	197.4	2677	2986
B1	2402343-4	15.26	141.91	272.0	1943	250.8	1791	5.1	194.7	2578	2876
B1	2403308-2	15.32	141.53	273.6	1954	251.6	1797	5.2	198.3	2908	3242
B1	2403308-3	15.32	141.53	273.8	1956	252.6	1804	5.3	191.1	2908	3242
B1	2403308-4	15.32	141.53	274.1	1958	255.1	1822	4.7	199.6	2908	3242
B1	2403308-5	15.32	141.53	273.6	1954	251.7	1798	5.0	198.8	2908	3242
B1	2403309-3	15.28	141.15	274.8	1963	254.2	1816	5.3	195.2	2647	2952
B1	2403309-4	15.28	141.15	274.7	1962	259.3	1852	4.8	199.2	2647	2952

Quality objection: The buyer shall notify the seller in writing by email of any non-conformity of the quantity or quality of the subject matter within three months after arrival at the port. Where the buyer delays in giving notice beyond the prescribed time limit, the quantity or quality of the subject matter is deemed to be in conformity with the contract.

Filed by :Zhangchunting

Approved by : Shenyingsiang