



MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24 MM
Standard: ASTM A416/A416M-15
Production Lisence No: XK 05-003-00098
Page No: 3/4
Inspection Date: SEP.22ND,2024
Invoice No: PCLPID2403C-1
Container No. APZU3572987

Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
10	2409128-4	15.23	140.51	275.1	1965	250.6	1790	5.4	194.8	2249	2510
10	2409129-6	15.26	140.51	274.6	1961	251.6	1797	5.1	196.8	2937	3274
10	2409130-6	15.24	140.51	268.4	1917	252.6	1804	5.3	197.2	2935	3272
10	2409131-6	15.25	140.64	271.6	1940	250.4	1789	5.2	195.8	3090	3444
10	2409351-1	15.24	140.64	267.1	1908	246.9	1764	4.9	197.3	3027	3374
10	2409351-5	15.24	140.64	268.5	1918	249.0	1779	4.9	199.0	2825	3150
10	2409356-4	15.24	140.51	270.5	1932	244.9	1749	5.5	192.6	2805	3128
10	2409356-5	15.24	140.51	270.3	1931	245.3	1752	5.6	190.6	2858	3186
10	2409134-6	15.25	140.89	272.4	1946	249.8	1784	5.7	191.0	2067	2308

Quality objection: The buyer shall notify the seller in writing by email of any non-conformity of the quantity or quality of the subject matter within three months after arrival at the port. Where the buyer delays in giving notice beyond the prescribed time limit, the quantity or quality of the subject matter is deemed to be in conformity with the contract.

Filled by :Zhangchunting



Approved by : Shenyingsiang