



MILL TEST CERTIFICATE

**Customer:** PRODALAM S.A.  
**Commodity:** PRESTRESSED CONCRETE STRAND  
**Nominal Diameter:** 15.24 MM  
**Standard:** ASTM A416/A416M-18  
**Production Lisence No:** XK 05-003-00098  
**Page No:** 1/4  
**Inspection Date:** SEP.22ND,2024  
**Invoice No:** PCLPID2403C-1  
**Container No.** TEMU4142164

Mark on Coil	Coil No.	Dia MM	Section Area (mm <sup>2</sup> )	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
8	2409354-2	15.24	140.64	272.0	1943	250.7	1791	5.1	196.0	3032	3380
8	2409354-3	15.24	140.64	271.7	1941	249.8	1784	5.4	192.1	2832	3158
8	2409354-4	15.24	140.64	270.6	1933	246.3	1759	5.3	196.1	2832	3158
8	2409354-5	15.24	140.64	270.9	1935	247.4	1767	5.2	194.8	2834	3160
8	2409354-6	15.24	140.64	271.0	1936	249.6	1783	5.5	191.0	3031	3378
8	2409355-4	15.30	141.78	269.0	1921	249.9	1785	4.5	196.3	2638	2942
8	2409134-1	15.25	140.89	273.2	1951	257.0	1836	4.8	192.0	2061	2302
8	2409134-4	15.25	140.89	271.9	1942	251.9	1799	5.2	196.0	2840	3166
8	2409134-5	15.25	140.89	271.7	1941	250.9	1792	5.3	198.7	2636	2940

Quality objection: The buyer shall notify the seller in writing by email of any non-conformity of the quantity or quality of the subject matter within three months after arrival at the port. Where the buyer delays in giving notice beyond the prescribed time limit, the quantity or quality of the subject matter is deemed to be in conformity with the contract.

Filled by :Zhangchunting

Approved by : Shenyingsiang

