



MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Licence No: XK 05-003-00098
Page No: 3/12
Inspection Date: OCT.21, 2022
Invoice No: PCLPY2203C
Container No. CMAU2169864



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
J3	2210384-5	15.25	140.64	272.0	1943	246.4	1760	5.4	198.6	2446	2724
J3	2210384-6	15.25	140.64	271.9	1942	246.2	1759	5.5	198.4	2446	2724
J3	2210384-7	15.25	140.64	271.7	1941	245.0	1750	5.6	196.8	2693	2998
J3	2210385-1	15.24	140.64	271.0	1936	250.7	1791	5.3	199.5	2440	2718
J3	2210386-6	15.27	141.02	272.6	1947	248.9	1778	5.4	196.7	2937	3268
J3	2210387-1	15.23	140.51	270.1	1929	247.4	1767	5.2	198.3	3045	3388
J3	2210387-2	15.23	140.51	270.4	1931	249.6	1783	5.4	191.2	2834	3154
J3	2210387-6	15.23	140.51	270.2	1930	249.3	1781	5.0	192.7	2913	3242
J3	2210528-2	15.25	141.02	272.4	1946	251.8	1799	5.0	194.7	2643	2942

Filed by :Zhangchunting

Approved by : Shenyingsiang